

## TABLE DEFINITIONS

Non-Detects (ND)- laboratory analysis indicates that the constituent is not present.

ND/Low- High- For water systems that have multiple sources of water, the Utah Division of Drinking Water has given water systems the option of listing the test results of the constituents in one table, instead of multiple tables. To accomplish this, the lowest and highest values detected in the multiple sources are recorded in the same space in the report table.

Parts per million (ppm) or #/ams per liter (mg/l)- one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter (ug/l)- one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Parts per trillion (ppt) or Nanograms per liter (nanograms/l)- one part per trillion corresponds to one minute in 2,000,000 years, or a single penny in \$10,000,000,000.

Parts per quadrillion (ppq) or Picograms per liter (picograms/l)- one part per quadrillion corresponds to one minute in 2,000,000,000 years or one penny in \$10,000,000,000,000.

Picocuries per liter (pCi/L)- picocuries per liter is a measure of the radioactivity in water.

Millirems per year (mrem/yr)- measure of radiation absorbed by the body.

Million Fibers per Liter (MFL)- million fibers per liter is a measure of the presence of asbestos fibers that are longer than 10 micrometers.

Nephelometric Turbidity Unit (NTU)- nephelometric turbidity unit is a measure of the clarity of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

Action Level (AL)- the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Treatment Technique (TT)- A treatment technique is a required process intended to reduce the level of a contaminant in drinking water.

Maximum Contaminant Level (MCL)- The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG)- The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL)- The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG)- The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Date- Because of required sampling time frames i.e. yearly, 3 years, 4 years and 6 years, sampling dates may seem outdated.

Waivers (W)- Because some chemicals are not used or stored in areas around drinking water sources, some water systems have been given waivers that exempt them from having to take certain chemical samples, these waivers are also tied to Drinking Water Source Protection Plans.

## MICROBIOLOGICAL CONTAMINANTS

**Antimony.** Some people who drink water containing antimony well in excess of the MCL over many years could experience increases in blood cholesterol and decreases in blood sugar.

**Arsenic.** Some people who drink water containing arsenic in excess of the MCL over many years could experience skin damage or problems with their circulatory system, and may have an increased risk of getting cancer.

While your drinking water meets EPA's standard for arsenic, it does contain low levels of arsenic. EPA's standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. EPA continues to research the health effects of low levels of arsenic which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Water samples taken in March 2021 confirmed the presence of total coliform bacteria. Total coliforms are common in the environment and are generally not harmful themselves. The presence of these bacteria is usually a result of a problem with water treatment or the pipes which distribute the water and indicates that the water may have been contaminated with organisms that can cause disease. Symptoms may include diarrhea, cramps, nausea, and possible jaundice, and any associated headaches and fatigue. When the monthly samples confirmed the presence of total coliform bacteria we took steps to identify and correct the problem. Subsequent monthly sampling has confirmed the absence of total coliforms in the water system.

## QUESTIONS

If you have any questions about this report or concerning your water utility, please contact Timm Dixon at 435-300-4159. We want our valued customers to be informed about their water utility.

## SOURCE PROTECTION PLAN

The Drinking Water Source Protection Plan for Hideout's water system is available for your review. It contains information about source protection zones, potential contamination sources and management strategies to protect our drinking water. Our sources have been determined to have a low level of susceptibility from potential contamination.

## CROSS CONNECTIONS

There are many connections to our water distribution system. When connections are properly installed and maintained, the concerns are very minimal. However, unapproved and improper piping changes or connections can adversely affect not only the availability, but also the quality of the water. A cross connection may let polluted water or even chemicals mingle into the water supply system when not properly protected. This not only compromises the water quality but can also affect your health. So, what can you do? Do not make or allow improper connections at your homes. Even that unprotected garden hose lying in the puddle next to the driveway is a cross connection. The unprotected lawn sprinkler system after you have fertilized or sprayed is also a cross connection. When the cross connection is allowed to exist at your home, it will affect you and your family first. If you'd like to learn more about helping to protect the quality of our water, call us for further information about ways you can help.

## LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Hideout's water system is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

## MCLs

MCLs are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

## POTENTIAL HEALTH RISK FOR DRINKING WATER

All sources of drinking water are subject to potential contamination by constituents that are naturally occurring or manmade. Those constituents can be microbes, organic or inorganic chemicals, or radioactive materials. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immunocompromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice from their health care providers about drinking water. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## OUR COMMITMENT

We at Hideout's water system work around the clock to provide top quality water to every tap. We ask that all our customers help us protect our water sources, which are the heart of our community, our way of life and our children's future.



# 2021 ANNUAL WATER QUALITY REPORT

We're pleased to present to you this year's Annual Drinking Water Quality Report. This report is designed to inform you about the quality of the water and services we deliver to you every day. Our constant goal is to provide you with a safe and dependable supply of drinking water. We want you to understand the efforts we make to continually improve the water treatment process and protect our water resources. We are committed to ensuring the quality of your water. Our water source has been determined to be from surface water sources. Our water source is Jordanelle SSD UTAH26086.

This report shows our water quality and what it means to you, our customer.

# Test Results

Hideout's Water System routinely monitors for constituents in our drinking water in accordance with the Federal and Utah State laws. The following table shows the results of our monitoring for the period of January 1st to December 31st, 2021. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

Contaminant	Violation Y/N	Level Detected ND/Low-High	Unit Measurement	MCLG	MCL	Date Sampled	Likely Source of Contamination
<b>MICROBIOLOGICAL CONTAMINANTS</b>							
Total Coliform	N	1	N/A	0	Presence of coliform bacteria in 5% of monthly samples	2021	Naturally Present in the environment
Fecal Coliform and E.Coli	N	ND	N/A	0	If a routine sample and repeat sample are total coliform positive, and one is also fecal coliform or E.coli positive	2021	Human and animal fecal waste
Turbidity for surface water	N	0.06-2.3	NTU	N/A	5	2019, 2021	Soil runoff
<b>INORGANIC CONTAMINANTS</b>							
Antimony	Y	ND-7.5	ppb	6	6	2020, 2021	Discharge from petroleum refineries; fire retardants; ceramics; electronics; solder; test addition
Arsenic	Y	1.2-50.8	ppb	0	10	2020, 2021	Erosion of natural deposits; runoff from orchards; runoff from glass and electronics production wastes
Barium	N	0.011-0.322	ppm	2	2	2020, 2021	Discharge of drilling wastes; discharge from metal refineries; erosion of natural deposits
Cadmium	N	ND-1.8	ppb	5	5	2020, 2021	Corrosion of galvanized pipes; erosion of natural deposits; discharge from metal refineries; runoff from waste batteries and paints
Carbon, Total Organic (TOC)	N	ND-0.6	ppm	0	4	2021	Naturally present in the environment
Chromium	N	ND-0.6	ppb	100	100	2020, 2021	Discharge from steel and pulp mills; erosion of natural deposits
Copper a. 90% results b. # of sites that exceed the AL	N	a. 0.006 b. 0	ppm	1.3	AL= 1.3	2019	Corrosion of household plumbing systems; erosion of natural deposits
Cyanide	N	ND-4.5	ppb	200	200	2020, 2021	Discharge from steel/metal factories; discharge from plastic and fertilizer
Fluoride	N	ND-0.367	ppm	4	4	2020, 2021	Erosion of natural deposits; water additive which promotes strong teeth; discharge from fertilizer and aluminum factories
Lead a. 90% results b. # of sites that exceed the AL	N	a. ND b. 0	ppb	0	AL= 15	2019	Corrosion of household plumbing systems; erosion of natural deposits
Nickel	N	ND-6.6	ppb	100	100	2020, 2021	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Nitrate (as Nitrogen)	N	ND-0.561	ppm	10	10	2021	Runoff from fertilizer use; leaching from septic tanks, sewage; erosion of natural deposits
Selenium	N	ND-2.9	ppb	50	50	2020, 2021	Discharge from petroleum and metal refineries; erosion of natural deposits; discharge from mines
Sodium	N	4.081-37.661	ppm	500	None set by EPA	2020, 2021	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills
Sulfate	N	6.914-263.053	ppm	1000	1000	2020, 2021	Erosion of natural deposits; discharge from refineries and factories; runoff from landfills; runoff from cropland
TDS (Total Dissolved Solids)	N	160-488	ppm	2000	2000	2020, 2021	Erosion of natural deposits
Thallium	N	ND-1.4	ppb	1	2	2020, 2021	Leaching from ore-processing sites; discharge from electronics, glass, and drug factories
<b>DISINFECTION BY-PRODUCTS</b>							
TTHM [Total trihalomethanes]	N	7.1-7.5	ppb	0	80	2021	By-product of drinking water disinfection
<b>RADIOACTIVE CONTAMINANTS</b>							
Alpha Emitters	N	ND-2.6	pCi/1	0	15	2020, 2021	Erosion of natural deposits
Radium 228	N	ND-0.7	pCi/1	0	5	2020, 2021	Erosion of natural deposits
<b>VOLATILE ORGANIC CONTAMINANTS</b>							
Ethylbenzene	N	ND-9.9	ppb	700	700	2020, 2021	Discharge from petroleum refineries
Styrene	N	ND-2.2	ppb	100	100	2020, 2021	Discharge from rubber and plastic factories; leaching from landfills
Toluene	N	ND	ppm	1	1	2020, 2021	Discharge from petroleum factories
Xylenes	N	ND-0.124	ppb	10	10	2020, 2021	Discharge from petroleum factories; discharge from chemical factories



June 23, 2022

Utah Department of Environmental Quality  
CCR Compliance, Division of Drinking Water  
P.O. Box 144830  
Salt Lake City, Utah 84114-4830  
ATTN: Brandi Smith

Dear Ms. Smith,

This letter certifies that the 2021 Consumer Confidence Report for Hideout Utah has been completed and distributed to our customers by email and posting on our Town website. Please contact me if there are any questions or concerns.

Best Regards,

Timm Dixon, P.E.  
Director of Engineering and Public Works  
Town of Hideout  
[tdixon@hideoututah.gov](mailto:tdixon@hideoututah.gov)